

Kurzanleitung

AP10T

Sollwertanzeige



Ausführlichere Dokumentationen unter <http://www.siko-global.com/p/ap10t>

Allgemeine Hinweise

Vor der Installation, einschließlich in Gefahrenbereichen, lesen Sie die Montageanleitung (Download Internet). Sie enthält die Sicherheitsvorschriften, Hinweise und technischen Daten, die bei der Installation zu beachten sind. Änderungen sind vorbehalten.

Vorsicht

Damit dieses Produkt zuverlässig funktioniert, muss es sachgemäß transportiert, aufbewahrt, positioniert und montiert werden. Es muss mit Sorgfalt betrieben und gewartet werden. Nur entsprechend qualifiziertes Personal darf dieses Produkt installieren und betreiben.

Sicherheitshinweise

Aus Sicherheitsgründen ist es wichtig, dass Sie die folgenden Punkte lesen und verstehen, bevor Sie das System installieren:

- Installation, Anschluss, Inbetriebnahme und Wartung ist von Personal auszuführen, das entsprechend qualifiziert ist.
- Es liegt in der Verantwortung des Kunden, dass das betreffende Personal vor der Installation des Gerätes die Anweisungen und Richtungsangaben in dieser Anleitung und in der Montageanleitung versteht und befolgt.
- Es liegt in der Verantwortung des Kunden, sicherzustellen, dass die Sollwertanzeige richtig angeschlossen und konfiguriert ist.
- Reparatur und Wartung ist nur von Personal durchzuführen, das von SIKO besonders geschult wurde.




SIKO GmbH
Weiherrmattenweg 2
79256 Buchenbach
www.siko-global.com

Telefon: +49 7661 394-0
Telefax: +49 7661 394-388
Service: support@siko.de

Mechanische Montage

Gerät über rückseitige Gewindebohrungen auf einer ebenen Auflagefläche befestigen.



Maß ød	2x M5, 7 mm tief
Maß L1	22
Maß L2	20 ±0.15


Elektrische Installation

Der Einsatzort ist so zu wählen, dass induktive oder kapazitive Störungen nicht auf die Sollwertanzeige oder dessen Anschlussleitung einwirken können!

- Alle Leitungen für die Sollwertanzeige müssen geschirmt sein. Litzenquerschnitt Leitungen $\geq 0.14 \dots \leq 0.5 \text{ mm}^2$.
- Anschlussverbindungen nicht unter Spannung schließen oder lösen.
- Verdrahtungsarbeiten spannungslos durchführen.
- Litzen mit geeigneten Aderendhülsen versehen.
- Vor dem Einschalten sind alle Leitungsanschlüsse und Steckverbindungen zu überprüfen.
- Leitungsführungen parallel zu Energieleitungen vermeiden. Schirmbleche oder metallisierte Gehäuse verwenden.
- Schützspulen müssen mit Funkenlöschgliedern beschaltet sein.

Anschlussbelegung

PIN	Belegung
1	DÜB/CANL
2	DÜA/CANH
3	+UB
4	GND/SGND



Inbetriebnahme

Die Sollwertanzeige verfügt über eine zweizeilige Anzeige, drei Bedientasten, eine Quittierungstaste und eine LED-Anzeige mit 2 LEDs.

Im Grundzustand wird in der oberen Zeile Sollwert 1 und in der unteren Zeile Sollwert 2 angezeigt.

Konfiguration

- Das Drücken der -Taste startet den Parametrier-/Programmiermodus. Im Konfigurations-Modus werden die erforderlichen Parameter eingestellt. Hierbei wird im Display in der 1. Zeile jeweils der Parameter und in der 2. Zeile der zugehörige Wert dargestellt.

Mit der -Taste kann der aktuelle Wert, bzw. bei mehrstelliger Werteingabe die blinkenden Stelle verändert werden.

Mit der -Taste wird bei mehrstelligen Zahlen zur nächsten Stelle weitergeschaltet.

Durch betätigen der -Taste wird der eingestellte Wert bestätigt und nichtflüchtig gespeichert. Wird keine Taste betätigt, so wird der Konfigurations-Modus nach ~30 s verlassen, ohne dass der zuletzt angezeigte Wert gespeichert wird, d. h. der ursprüngliche Wert bleibt erhalten.

Konfigurationsparameter CAN

Parameter	Wertebereich	Default	Bedeutung/Bemerkung
ID	1 ... 127	125	Bus-Adresse ACHTUNG Nach Änderung des Parameters muss ein Neustart durchgeführt werden!
KBAUD	125, 250, 500, 800, 1000kbaud, Auto	Auto	CAN Baudrate (z. B. 250 kbit/s)

Konfigurationsparameter RS485

Parameter	Wertebereich	Default	Bedeutung/Bemerkung
ID	1 ... 127	31	Bus-Adresse ACHTUNG Nach Änderung des Parameters muss ein Neustart durchgeführt werden!
KBAUD	19.2, 57.6, 115.2	57.6	SIKONETZ Baudrate (z. B. 57.6 kbit/s)

Weitere Konfigurationsparameter sind den ausführlichen Dokumentationen zu entnehmen.

Technische Daten

Elektrische Daten	Ergänzung
Betriebsspannung	24 V DC ±20 %
Stromaufnahme	~30 mA bei Betrieb mit LEDs zuzüglich ~3 mA pro LED

Quick Start Guide

AP10T

Setpoint display



For detailed documentation please refer under <http://www.siko-global.com/p/ap10t>

General information

Prior to installation, including in hazard areas, read the Installation Instructions (download from the internet). It contains the safety instructions, hints and technical data to be observed during installation. Subject to change without notice.

⚠ Caution

In order to ensure reliable functioning of this product, take care to transport, store, position and mount it appropriately. Exercise care when you operate and maintain the device. Only properly qualified personnel is authorized to install and operate this product.

Safety information

It is important for safety reasons that you read and understand the below instructions before you install the system:

- Installation, connection, commissioning and maintenance shall be done by properly qualified personnel.
- It is the responsibility of the customer to ensure that the personnel concerned read and follow the instructions and directions of this Guide and of the Installation Instructions.
- It is the responsibility of the customer to ensure that the setpoint display is correctly connected and configured.
- Only personnel specifically trained by SIKO shall execute repair and maintenance work.




SIKO GmbH
Weiherrmattenweg 2
79256 Buchenbach
www.siko-global.com

Phone: +49 7661 394-0
Fax: +49 7661 394-388
Service: support@siko.de

Mechanical mounting

Fasten the device via the threaded holes on the rear on a level support.



dim. $\varnothing d$	2x M5, 7 mm deep
dim. L1	22
dim. L2	20 ±0.15


Electrical Installation

The location should be selected to ensure that no capacitive or inductive interferences can affect the setpoint display or the connection lines!

- All lines for connecting the setpoint display must be shielded. Strand cross sections of lines $\geq 0.14 \dots \leq 0.5 \text{ mm}^2$.
- Do not disconnect or close live connections.
- Perform wiring work in the de-energized state only.
- Use strands with suitable ferrules.
- Prior to switching on check all mains and plug connections.
- The running of wiring parallel to the mains supply should be avoided. Use screening shields or metallized housings.
- Contactor coils must be linked with spark suppression.

Pin assignment

PIN	Designation
1	DÜB/CANL
2	DÜA/CANH
3	+UB
4	GND/SGND



Commissioning

The setpoint display features a two-row display, three operating keys, an acknowledgment key and an LED display with two LEDs.

In the basic state, setpoint 1 is displayed in the upper row and setpoint 2 is displayed in the lower row.

Configuration

- Pressing the key starts the parameter / programming mode.

The required parameters are set in the configuration mode. On the 1st line of the display, the parameter will be shown and on the 2nd line the respective value will be displayed.

Press key for changing actual value and / or the blinking digit when entering a multi-digit value.

The key serves for switching to the next digit in case of multi-digit numbers.

By pressing the key, the set value is acknowledged and saved non-volatilely. If no key is pressed, the configuration mode will be exited after ~30 s without saving the latest value displayed, i. e. the original value will be maintained.

Configuration parameters CAN

Parameter	Value range	Default	Meaning/Remark
ID	1 ... 127	125	bus address NOTICE Restart is required after changing these parameters!
KBAUD	125, 250, 500, 800, 1000kbaud, Auto	Auto	CAN baud rate (e. g. 250 kbit/s)

Configuration parameters RS485

Parameter	Value range	Default	Meaning/Remark
ID	1 ... 127	31	bus address NOTICE Restart is required after changing these parameters!
KBAUD	19.2, 57.6, 115.2	57.6	SIKONETZ baud rate (e. g. 57.6 kbit/s)

Additional configuration parameters can be found in the detailed documentation.

Technical data

Electrical data	Additional information	
Operating voltage	24 V DC ±20 %	
Current consumption	~30 mA	if operated with LEDs, additional ~3 mA per LED